



**Underwriters
Laboratories Inc.®**

Northbrook Division
333 Pfingsten Road
Northbrook, IL 60062-2096 USA
www.ul.com
tel: 1 847 272 8800
fax: 1 847 272 8129
Customer service: 1 877 854 3577

NORBULB SPRINKLER ELEMENTE GMBH
MR N JOB
ROBERT-KOCH-STR 25A
22851 NORDERSTEDT GERMANY

Your most recent Certification is shown below. You may also view this information, or a portion of this information (depending on the product category), on UL's Online Certifications Directory at www.ul.com/database. Please review the text and contact the Conformity Assessment Services staff member who handled your project if revisions are required. For instructions on placing an order for this information in a 3 x 5-inch format, you may refer to the enclosed order form for UL Card Service.

VNIV2 March 18, 2004
Sprinklers, Automatic and Open - Component

NORBULB SPRINKLER ELEMENTE GMBH
ROBERT-KOCH-STR 25A, 22851 NORDERSTEDT GERMANY

EX5080

Glass Bulb Heat Responsive Element.

Model

N5
N3
N3.3

Temperature Rating F

135, 155, 175, 200, 286, 360
135, 155, 175, 200, 286
135, 155, 175, 200, 286

Marking: Company name, model designation and UL Recognition Mark.

See General Information Preceding These Recognitions
For use only in equipment where the acceptability of the combination is determined by Underwriters Laboratories Inc.

